



CASE STUDY TITLE

Wastewater Treatment and Reuse Using a Constructed Wetland System at Institutional Level

SUMMARY

The objective of this case study is to demonstrate how standards can be used for wastewater treatment and re-use. This supports the achievement of SDG target 6.3 on improving water quality by reducing pollution, eliminating dumping and minimizing the release of hazardous chemicals and materials.

The government of Botswana involved the Department of Water Affairs Headquarters, which used national standards based on international standards, to treat wastewater discharged from its own headquarters for re-use.

Wastewater reuse promotes water conservation & demand management which is one of Botswana's priorities for additional water resources. The demonstration project on wastewater treatment and reuse acts as a leverage towards improving wastewater re-use by various stakeholders. This includes public knowledge on safety and hygiene in handling wastewater. Wastewater reuse at the institutional level closes the water cycle loop.

This reduces pressure on freshwater usage as well as wastewater discharge into natural water resources, increasing water efficiency and preventing pollution.

BACKGROUND

Botswana is faced with water shortages due to its limited water resources. The situation is exacerbated by low rainfalls, high evaporation rates, poor water quality that is caused by the salinity of underground water, and water wastages,

AT A GLANCE

COUNTRY

- Botswana

LEVEL

- National

SDG ADDRESSED

- SDG 6 - Clean Water & Sanitation

especially in institutions such as schools. The country has reached its full potential in terms of surface water development (construction of dams). All Botswana's perennial rivers are shared with neighbouring countries.

These rivers are Okavango, Zambezi, Orange-Senque and Shashe - Limpopo. As an economy in transition, Botswana requires water for economic growth in domestic, energy, agriculture, tourism, manufacturing and the mining sectors hence wastewater reuse is an alternative source of water.



STRATEGY

The effluent produced by the constructed wetland system is assessed for quality in accordance with the national water quality standards. These are the drinking water quality specifications (BOS32: 2015), wastewater discharge requirements (BOS 93: 2012) and the water quality for irrigation specifications (BOS 463:2011). These standards were developed in Botswana by the Water Quality Technical Committee through the Botswana Bureau of Standards. The collection of samples from the wetland system is carried out in accordance with water quality sampling standards (BOS ISO 5667) which provide guidance on sampling wastewaters, sampling techniques, sample handling and preservation and guidance on the design of sampling programmes. Sampling, handling of samples in the field, their preservation and transportation to the laboratory for testing are also guided by the BOS ISO/IEC 17025 for the Competence of Testing and Calibration Laboratories. The first trial diverted wastewater into a constructed wetland ecosystem for treatment. This is a process where solids are removed from wastewater using septic tanks and the liquid is passed through a reed bed system that consists of four beds running in parallel and receiving the same load. Three of the beds contain different types of reeds that remove nutrients such as phosphates and nitrates while the fourth contains only sand and is used as a control

RESULTS & IMPACT

The constructed wetland system was found to be effective in treating wastewater for non-potable uses such as irrigation, construction and dust suppression. It was highlighted that different plant species in the reed beds have different affinities for nutrients in wastewater. However, constructed wetland system was

not effective in pathogen removal in wastewater hence coupling the system with disinfection reduced the micro-organisms to acceptable levels suitable for non-potable re-use option. In conclusion, the system when coupled with membrane filtration can treat wastewater to the acceptable water quality standards.

CHALLENGES & LESSONS LEARNED

Constant breakdowns and blockages of the system disrupt water flows, and this affects the systematic effluent sampling and quality monitoring. Low uptake of wastewater re-use by the various stakeholders due to social, cultural and religious beliefs is a challenge. Extensive research is required on wastewater re-use to determine technologies that can improve wastewater quality for the intended use, establish the consequences on cumulative pollution over extended use, as well as energy and nutrient recovery.

POTENTIAL FOR REPLICATION

Treatment of wastewater using a constructed wetland can be replicated by various institutions in Botswana to treat wastewater on site for reuse for non-potable uses.

CASE STUDY DEVELOPED BY:
Kene Carol Dick
Principal Water Chemist
Department of Water & Sanitation
Botswana

